



NO. 2011-01-0117-2

## Report of the Requested Test

### 1. Client

Name : Sung-sik, Moon  
 Manufacture : Hueintek, Inc.  
 Address : 621-18, Noha-ri, Paltan-myeon, Hwaseong-si, Gyeonggi-do  
 Korea (445-909)

2. **Product(sample)** : T-MAX 32K 50T(Polyester Acoustic Insulation)

3. **Request Date and Number** : No. 1012960, December 22, 2010

### 4. Test Results

Items	Standards	Test Results			Reference
		1	2	3	
After flame time	Less than 5 sec	0.0	0.0	0.0	
After glow time	Less than 20 sec	0.0	0.0	0.0	
Char area	Less than 40 cm <sup>2</sup>	32.6	30.4	39.0	
Char length	Less than 20 cm	7.8	7.7	9.5	


※ Above the result is tested by KOFEIS 1001

※ Use : Control the quality of product

Reference : 1. This is to certify that the tested sample has been requested by the above mentioned manufacturer.

2. This result can't be used an advertisement, a lawsuit etc.,

Date : January 11, 2011

President : 

**Korea Fire Industry Technology Institute**